

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. BDP-182

Dated: 19.04.24

It is certified that an inspection team headed by Memehoubisinha Asst Chemist (Name of Officers with designation) from Badarpur SDLL PHED inspected the Central Public School, Badarpur (Name & Address of the school) on 18.04.2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no BDP 182 Dated 18.04.24 of Badarpur SDLL (PHED Lab) certified that Central Public School, Badarpur (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till Six months from the date of experiment.

Mulisha  
Lab. Asstt. Chemist (PHE,  
Badarpur, Sub-Division  
Badarpur

Signature with Seal

Name

Designation

Name & Address of the Office / Department: Office of the A.B.R.

Badarpur Sub-Division  
Badarpur

To

Central Pubic School, Badarpur  
Umarpur, Badarpur.

(Name &amp; Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Attested  
Shy

Principal  
CENTRAL PUBLIC SCHOOL  
BADARPUR





**SUB DIVISIONAL LEVEL LABORATORY, BADARPUR**  
**ADDRESS:- OFFICE OF THE ASSTT. EXECUTIVE ENGINEER(PHE)**  
**BADARPUR SUB-DIVISION, BADARPUR**  
**Email:- badarpursdll@gmail.com**

**TEST REPORT**

Test report No :- BDP 182 Issue date:- 19.04.24  
 Issued to :- Central Public School, Badarpur  
 Sample Description :- drinking water  
 Sample collected on dated :- 18.04.24 Sample type :- Boring Water  
 Sample received on dated :- 18.04.24 Sample collected by :- Kamal Khan  
 Sample quantity :- 1.0 Ltr. Sample location :- Umarpur  
 Date of Analysis started :- 18.04.24 Date of Analysis completed :- 19.04.24

Sl. No.	Parameter	Results	IS:10500-2012 (Second Revision)		Unit
			Desirable limit	Max. Permissible limit (in absence better alternate source)	
1.	pH	6.92	6.5 to 8.5	No Relaxation	pH Units
2.	Turbidity	5.00	1	5	NTU
3.	Total Alkalinity	75.00	200	600	Mg/L
4.	Chloride	20.00	250	1000	Mg/L
5.	Total Hardness	15.00	200	600	Mg/L
6.	Fluoride	0.00	1	1.5	Mg/L
7.	Residual Chlorine	0.00	0.2	0.4	Mg/L
8.	Nitrate	—	45	45	Mg/L
9.	Sulphate	—	200	400	Mg/L
10.	TDS	132.00	500	2000	Mg/L
11.	Iron	0.04	1	No Relaxation	Mg/L
12.	E-coli	0.00	0	0	---
13.	Colour	5	5	15	Hazen
14.	Taste	Agreeable	Agreeable	Agreeable	---
15.	Odour	Agreeable	Agreeable	Agreeable	---

**Remarks:-** This water is safe from above analysis parameters.

**Notes:-**

- The results given above are related to the sample as received and tested in the laboratory. Reliability of sample lies with the sander.
- The test report cannot be regenerated /re-produced in whole or in part without written permission of laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test sample meant for chemical analysis will be disposed of after 15 (fifteen) days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer.

**END OF TEST REPORT**

*Attested*  
*Shy*

Principal  
 CENTRAL PUBLIC SCHOOL  
 BADARPUR

*M. K. S.*  
 Asstt. Chemist  
 SDLL, Badarpur  
 Lab. Asstt. Chemist (PHE)  
 Badarpur, Sub-Division  
 Badarpur





GOVERNMENT OF ASSAM

**OFFICE OF THE  
SUB-DIVISIONAL MEDICAL & HEALTH OFFICER  
KACHUADAM BLOCK PHC, KARIMGANJ:: ASSAM**

No. KPHC/2024-2025/08

Date : 18/04/2024

**TO WHOM IT MAY CONCERN**

This is to certify that Health, Hygiene and Sanitary condition of CENTRAL PUBLIC SCHOOL, Umarpur, Badarpur, Dist – Karimganj (Assam), is satisfactory. Building condition is good RCC type with three (3) floors. The building as a whole is well ventilated. Sanitary Latrine with urinal for both Boys and Girls are separately made of RCC type with the adequate consumption of water in the tank. The drinking water source of the school is from P.H.E deptt and apart from that school has well maintained tube well. The Hygienic environment has been maintaining in the school.

There is no obvious objection from Health, Hygiene and Sanitation point.

*Attested*

*Shmy*  
*18/04/2024*

Principal  
CENTRAL PUBLIC SCHOOL  
BADARPUR

*Shmy*  
*18/04/24*

SDM & HO  
Kachuadam BPHC  
SDM & H.O  
KACHUADAM PHC