SUB DIVISIONAL LEVEL LABORATORY, BADARPUR ADDRESS:- OFFICE OF THE ASSTT. EXECUTIVE ENGINEER(PHE) BADARPUR SUB-DIVISION, BADARPUR

Email:- badarpursdll@gmail.com

TEST REPORT

24.6.25 Issue date:-:- 297
Issue date::- Central Public School, Badarpus
:- Drunking Walti
:- 23.0625 Sample type
:- 23.0625 Sample collected by :- kamal khan
:- 2.0 Ltr Sample location :- Srigouri, Badarpus
:- 23.0625 Date of Analysis completed :- 24.0625 Test report No Issued to Sample Description Sample collected on dated Sample received on dated Sample quantity Date of Analysis started

Sl. No.	Parameter	Results	IS:10500-2012 (Second Revision)		
			Desirable limit	Max. Permissible limit (in absence better alternate source)	Unit
1.	pH	6.98	6.5 to 8.5	No Relaxation	pH Units
2.	Turbidity	4.00	1	5	NTU
3.	Total Alkalinity	75.00	200	600	Mg/L
4.	Chloride	20.00	250	1000	Mg/L
5.	Total Hardness	24.00	200	600	Mg/L
6.	Fluoride	0.00	1 1	1.5	Mg/L
7.	Residual Chlorine		0.2	0.4	Mg/L
8.	Nitrate	- 1 Total	45	45	Mg/L
9.	Sulphate		200	400	Mg/L
10.	TDS	138.22	500	2000	Mg/L
11.	Iron	0.04	1	No Relaxation	Mg/L
12.	Arsenic		0	0.01	Mg/L
13.	E-coli		0	0	
14.	Colour	5.00	5	15	Hazen
15.	Taste	Agreeable	Agreeable	Agreeable	
16.	Odour	Agreeshe	Agreeable	Agreeable	

Remarks:- The water is safe for drinking purpose un from about analysis parameters.

Notes:-

a. The results given above are related to the sample as received and tested in the laboratory. Reliability of sample lies with the sander.

b. The test report cannot be regenerated /re-produced in whole or in part without written permission of laboratory.

c. The test report cannot be used for any publicity or any legal purpose.

d. The test sample meant for chemical analysis will be disposed of after 15 (fifteen) days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer.

